

1. Wechselrichter

- Folgen Sie der Gebrauchsanleitung des Herstellers sorgfältig.

2. Lage des Gestells auf Flachdach

- Vermeiden Sie, das Gestell an einem Ort zu installieren, der völlig dem Wind ausgesetzt ist.
- Der empfohlene Sicherheitsabstand zur Dachkante ist 3 Meter.
- Überprüfen Sie vor der Montage die Lage der Dachdeckung.
- Der Untergrund soll flach sein und ausreichend tragfähig sein (Eigengewicht Gestell + Wechselrichter).

3. Ballast

- Der Shelter kann nicht umkippen, falls er ausreichend gesichert ist
- Die im Anhang genannten Vorschriften bezüglich Ballastierung müssen respektiert werden.

4. Elektrische Erdung

- Aus Sicherheitsgründen muss der Shelter geerdet sein.
- Das sind die geltenden nationalen Anforderungen für elektrische Installationen.

5. Blitzschutz

- Blitzschutz spielt eine wesentliche Rolle im vorbeugenden Brandschutz.
- Die Montage eines PV-Systems auf einem Dach erhöht die direkte Wahrscheinlichkeit eines Blitzschlags nicht.
- Die blitzstromführenden Teile werden an die anwesenden Blitzableiter angeschlossen. Das bedeutet, dass Spannungsübertragung oder Funken nicht auftreten. Dadurch gibt es kein erhöhtes Risiko auf Brand durch Blitzschlag.
- Kontaktieren Sie im Zweifelsfall einen anerkannten Blitzschutzinstallateur.



3. DECLARATION OF CONFORMITY



Oudenaarde, 14 January 2019

EC DECLARATION OF CONFORMITY

Producer: TRAYCO nv
Product description: Cable management systems

We declare that our products are in conformity with the rules of the essential requirements of the EC directive:

- 2014/35/EU (low voltage)

Applicable national standards and technical specifications:

- CEI IEC 61537

Technical documentation is available at the manufacturer location.

Geert Ballet

Vast vertegenwoordiger Gebamet bvba
CEO Trayco NV
Managing Director

On condition that the products are used in the manner intended and/or in accordance with the current installation standards and/or with the recommendations of the manufacturer.

TRAYCO NV • Bedrijvenpark Coupure 5A, B-9700 Oudenaarde
t. +32(0)55 23 29 90 - info@trayco.eu - www.trayco.eu
BTW BE0878 370 830 - RPG Gent afdeling Oudenaarde
Algemene voorwaarden: zie ommezijde

Invoice has been absolutely assigned to: ING Commercial Finance Belux N.V./S.A. -
Marnixlaan 24 - 1000 Brussels / Exclusively payable on account number:
IBAN BE79370115783533 - BIC BBRUBEBB / Any dispute regarding this invoice has to be
reported to the above mentioned entity t. +32 2 739 88 18 - f. + 32 2 739 89 85